DEPARTMENT OF
FINANCIAL SERVICES

ADDENDUM# 1
REPLACEMENT WINDOWS & EXTERIOR REPAIRS AT FIRE STATION #3

Bid # 6231F

November 30, 2011

Dear Vendors:

The Contract Bidding Documents pursuant to Bid # 6231F are hereby revised as follows:

- **Glass for all windows in stairwells shall be tempered insulating glass.**

The following clarifications are in response to RFI's received:

Q1: Is the trim to be included in the base bid or is it part of the alternate? If it is in the base bid what are the materials to be used?

A1: Cedar Trim is part of the base bid. There is a PVC alternate to the Cedar.

Q2: On sheet "A-1" information for window type "F" is given but it is not tagged on the elevations, does this type exist?

A2: On sheet A-1 window type "F" does not exist.

Q3: On sheet "A-1" the rough opening for window type "E" doesn't match what is shown on the elevation on sheet "A-2", which is correct?

A3: On sheet A-1 rough opening for window type "E" should be approximately 5'-9"w x 5'-6"h.

Q4: On sheet "A-3" window type "H" is tagged but the description doesn't exist on sheet "A-1", please clarify.

A4: On sheet A-3 window type "H" should have a rough opening approximately 9'-4"w x 6'-3"h

Q5: 00402-16 pollution coverage: Is it necessary?

A5: The windows have not been tested for any hazardous materials. It is assumed that Lead exists. However we cannot be certain of any other contaminants. That being said, we would recommend having the proper coverage.

Thank you for your patience, time and consideration.

Sincerely,

Tammy Bradley

Tammy Bradley, CPM, C.P.P.B.
Sr. Buyer

C: Joe Mercieri, Capitol Projects Manager
Peter Chow, Oak Park Architects LLC

TOWN OF WEST HARTFORD 50 SOUTH MAIN STREET
TOWN OF WEST HARTFORD, CT 06107-2431
(860) 561-7470 FAX: 561-7492

Printed on Recycled Paper

TOWN OF WEST HARTFORD